

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年2月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	10.30	2.29	65.08	2.07	7.66	2.38	23724.52	147.71
02	11.26	2.17	66.00	0.90	7.51	2.40	23590.26	151.63
03	11.65	1.90	65.66	1.22	7.42	2.46	23881.12	150.19
04	8.77	1.75	63.88	2.54	7.30	2.53	24129.55	151.13
05	8.04	2.13	64.05	2.62	7.43	2.50	23694.77	152.11
06	9.30	2.25	67.13	4.34	7.81	2.25	23239.11	154.19
07	7.18	2.24	66.62	5.81	7.84	2.30	23433.49	151.71
08	8.65	2.13	66.15	5.40	7.89	2.31	23047.25	153.02
09	8.27	2.39	65.63	4.24	7.70	2.28	23315.54	152.14
10	9.74	2.21	65.77	3.79	7.73	2.27	23200.88	152.14
11	10.16	3.19	66.92	5.65	7.70	1.84	23411.75	151.84
12	8.95	2.20	67.27	6.28	7.89	1.36	22998.66	153.96
13	8.96	2.55	66.11	5.24	7.98	1.39	22721.96	151.83
14	10.32	2.92	65.42	5.59	7.82	1.42	23085.68	149.10
15	10.83	2.23	64.95	5.23	7.60	1.49	23257.95	153.75
16	8.23	3.71	65.68	2.97	7.67	1.50	23291.67	151.39
17	8.90	2.34	66.51	4.52	7.56	1.47	23198.98	152.75
18	9.33	2.45	64.83	3.85	7.51	1.47	23255.18	153.30
19	7.90	2.35	63.94	3.02	7.18	1.45	23817.40	153.42
20	8.90	2.07	65.44	4.57	7.46	1.33	23638.92	153.99
21	6.48	2.81	63.74	4.17	7.67	1.33	22892.27	154.03
22	4.94	1.99	64.32	3.11	7.42	1.51	23921.37	155.17
23	5.38	1.46	62.43	3.51	7.14	1.59	24254.28	155.37
24	6.39	1.52	62.03	4.33	7.21	1.73	24073.52	155.19
25	8.62	1.69	63.85	6.75	7.26	1.79	24027.04	154.99
26	6.45	1.58	64.42	5.35	7.25	1.77	24085.43	155.91
27	6.32	1.53	66.13	4.00	7.66	1.81	23564.47	155.18
28	6.19	1.93	67.05	5.19	7.93	1.87	23401.27	155.61
29								
30								
31								
平均值	8.44	2.21	65.25	4.15	7.58	1.85	23505.51	152.96
最大值	11.65	3.71	67.27	6.75	7.98	2.53	24254.28	155.91
最小值	4.94	1.46	62.03	0.90	7.14	1.33	22721.96	147.71
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	217.65	43.44	2111.82	188.88				