

嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年2月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	12.68	3.31	68.03	0.27	9.49	2.40	20996.89	156.37
02	13.59	2.63	69.06	0.10	9.32	2.42	21341.89	158.28
03	13.68	2.87	66.57	0.13	9.08	2.46	22003.00	158.60
04	12.43	3.07	65.40	0.21	8.77	2.48	22690.38	158.70
05	12.00	2.58	62.11	0.14	8.34	2.52	22845.20	158.16
06	13.05	3.28	62.18	0.52	8.35	2.54	23113.46	160.79
07	14.17	3.82	63.95	1.35	8.73	2.56	22608.86	157.73
08	14.35	4.04	64.16	1.72	8.87	2.62	22370.48	160.86
09	13.87	3.19	64.24	1.37	8.57	2.69	22775.69	160.92
10	13.57	3.21	63.86	0.77	8.28	2.75	22962.56	157.44
11	13.61	3.29	66.64	1.31	8.41	2.14	22804.57	156.73
12	16.22	3.54	67.39	1.49	8.50	1.56	22899.62	158.75
13	8.99	4.13	67.79	5.16	8.97	1.65	21896.96	159.37
14	10.51	5.10	68.10	5.98	9.16	1.72	21278.27	159.93
15	11.40	4.98	68.66	6.29	8.98	1.75	21438.03	160.57
16	10.10	5.57	68.87	4.42	9.11	1.77	21462.31	158.68
17	8.94	3.43	69.42	4.75	9.04	1.80	21697.57	158.51
18	8.08	3.00	68.54	4.48	8.93	1.83	21829.06	158.67
19	8.41	2.69	68.66	4.21	8.54	1.86	22471.48	158.25
20	7.55	3.09	67.84	3.35	8.42	1.90	23077.01	158.81
21	6.71	4.91	68.17	3.54	8.72	1.95	22367.44	160.25
22	4.33	3.58	68.24	2.02	8.59	2.04	23137.29	160.78
23	5.03	3.03	66.56	1.54	7.92	2.14	24133.09	160.60
24	6.18	2.87	66.75	2.05	7.75	2.25	25062.44	161.66
25	7.05	3.83	66.27	3.61	7.82	2.32	24407.74	160.13
26	5.66	4.15	67.17	2.37	7.66	2.41	24868.72	161.13
27	4.70	3.47	66.04	1.24	7.61	2.48	24911.16	160.07
28	8.35	4.06	65.80	5.69	7.62	2.55	24991.05	160.52
29								
30								
31								
平均值	10.19	3.60	66.66	2.50	8.56	2.20	22801.51	159.33
最大值	16.22	5.57	69.42	6.29	9.49	2.75	25062.44	161.66
最小值	4.33	2.58	62.11	0.10	7.61	1.56	20996.89	156.37
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	252.04	68.62	2091.47	109.19				