

# 嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年3月

文件編號

煙囪編號:

P001

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	5.72	2.05	66.46	7.29	7.78	2.44	23745.94	156.10
02	7.19	1.58	64.95	3.62	7.51	3.47	23853.54	155.83
03	4.78	1.50	66.21	2.06	7.65	3.89	23723.35	155.32
04	5.66	1.85	65.79	2.54	7.48	4.13	23931.23	155.48
05	5.76	1.88	62.91	1.52	7.23	3.25	24107.84	154.96
06	7.08	2.21	63.67	3.81	7.66	1.41	23755.19	155.05
07	6.42	1.68	62.64	5.49	7.64	1.38	23531.70	154.46
08	4.43	1.65	61.46	4.16	7.41	1.37	23775.85	154.68
09	4.53	1.51	62.79	4.19	7.38	1.37	23825.63	154.49
10	6.35	1.54	65.10	4.72	7.47	1.36	23638.86	154.46
11	7.63	2.66	63.95	6.25	7.37	1.42	23632.82	154.02
12	6.63	1.83	64.91	5.39	7.51	1.39	23362.28	153.46
13	9.23	1.48	63.39	7.12	7.71	1.28	23305.53	154.47
14	9.12	1.39	62.53	9.15	7.65	1.32	23394.68	154.11
15	9.75	1.45	63.84	7.17	7.55	1.32	23560.31	153.59
16	7.33	1.25	65.56	5.38	7.90	1.38	23059.61	154.84
17	7.06	1.14	64.54	5.01	7.90	1.33	23235.18	155.21
18	8.95	1.32	63.68	6.88	7.47	1.43	23719.88	154.99
19	11.27	1.19	64.70	7.16	7.45	1.44	23615.29	154.20
20	10.54	1.09	64.34	6.59	7.56	1.45	23793.59	156.46
21	11.70	1.27	65.10	8.85	7.77	1.57	23471.80	156.24
22	10.18	1.50	65.32	8.30	7.70	1.67	23704.63	156.00
23	10.56	1.27	66.22	7.97	7.91	1.69	23193.17	154.86
24	8.46	1.16	64.03	5.49	7.61	1.81	23851.26	155.63
25	10.51	1.14	64.99	7.43	7.54	1.86	23926.84	154.25
26	10.54	0.95	64.42	6.86	7.45	1.84	23845.38	154.74
27	8.53	1.18	64.20	5.38	7.43	1.82	23991.50	154.98
28	11.57	1.39	64.38	8.84	7.25	1.78	24106.05	156.10
29	8.41	1.47	63.73	6.82	7.42	1.80	23783.22	159.44
30	8.78	1.27	65.21	6.97	7.47	1.81	23896.14	154.80
31	3.79	1.17	64.45	1.84	7.35	1.81	24204.46	157.84
平均值	8.01	1.48	64.37	5.81	7.55	1.85	23694.93	155.20
最大值	11.70	2.66	66.46	9.15	7.91	4.13	24204.46	159.44
最小值	3.79	0.95	61.46	1.52	7.23	1.28	23059.61	153.46
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	230.17	32.72	2325.91	292.86				