

# 嘉義市垃圾焚化廠CEMS煙囪監測系統月報

資料日期 115年3月

文件編號

煙囪編號:

P002

測項	氯化氫	一氧化碳	氮氧化物	二氧化硫	氧氣	不透光率	流速/流率	溫度
日/單位	ppm	ppm	ppm	ppm	%	%	m3/hr	°C
01	6.24	3.89	65.73	3.27	7.73	2.60	24892.95	161.63
02	7.42	3.76	64.73	3.19	7.63	2.64	24852.24	160.79
03	6.22	3.83	65.20	2.42	7.65	2.66	24670.47	160.05
04	6.41	3.84	66.29	2.53	7.70	2.70	24982.52	161.54
05	5.96	3.23	63.92	2.22	7.68	2.76	24626.31	160.23
06	7.66	3.17	66.04	3.03	7.53	2.81	25024.29	161.23
07	6.48	3.16	65.60	6.31	7.60	2.88	24438.10	160.74
08	6.45	3.26	66.34	2.65	7.88	2.97	24420.53	161.15
09	6.48	3.17	66.04	2.23	8.06	3.00	24281.02	159.81
10	5.69	3.29	64.74	2.15	7.70	3.07	24556.27	159.27
11	7.70	3.92	66.24	3.42	7.94	3.15	24515.34	161.06
12	7.00	4.36	68.17	3.75	8.13	2.56	24335.96	160.61
13	8.54	3.51	65.53	6.05	7.91	1.93	24333.94	159.14
14	9.06	3.07	66.18	7.55	7.83	2.07	24316.49	159.07
15	9.35	3.24	66.94	5.63	7.87	2.15	24282.17	159.49
16	4.81	3.45	66.46	3.37	8.11	2.21	24176.96	160.11
17	5.83	3.08	66.48	3.42	7.78	2.30	24371.40	159.74
18	8.42	3.15	66.86	5.26	7.75	2.04	24338.34	160.20
19	11.50	2.50	67.22	5.67	8.02	1.81	23717.28	160.04
20	9.30	2.99	67.62	5.25	8.29	1.91	23514.61	159.32
21	11.58	2.96	68.79	8.49	8.35	1.98	23250.48	160.39
22	8.61	3.15	68.26	6.97	8.34	2.06	23550.83	160.31
23	10.63	3.01	67.78	7.80	8.50	2.12	23034.63	161.15
24	5.38	3.20	67.24	4.02	8.17	2.20	23648.16	160.28
25	9.12	3.41	67.26	6.43	8.06	2.29	23315.30	159.60
26	9.00	2.91	67.68	6.08	8.36	2.39	23094.15	159.88
27	6.37	3.40	67.97	4.74	8.57	2.46	22978.53	159.94
28	7.95	3.78	66.55	8.59	8.68	2.54	22379.46	161.27
29	3.36	3.46	67.25	6.38	8.58	2.61	22652.46	159.91
30	4.69	3.44	67.49	7.49	8.70	2.71	22569.84	159.59
31	2.40	3.87	68.14	3.13	8.46	2.81	22793.50	159.87
平均值	7.28	3.37	66.67	4.82	8.05	2.46	23932.73	160.24
最大值	11.58	4.36	68.79	8.59	8.70	3.15	25024.29	161.63
最小值	2.40	2.50	63.92	2.15	7.53	1.81	22379.46	159.07
排放標準	<60.00	<150.00	<85.00	<150.00		<10.00		
月排放量	211.04	74.96	2431.32	243.48				